

PARTICIPANTS

This course is aimed at process control engineers who are involved in the design, implementation and operation of any control system in a plant. No previous contact with process simulation software is required. The attendee should know basic chemical engineering principles (or equivalent plant experience) and process control fundamentals. It is also desirable knowledge of control/operation of distillation columns and 1-2 years of experience in process control roles.

CONTENTS

During the course, control engineers will learn the fundamentals of Steady State and Dynamic Process Simulation concepts and will practice with them, always from the point of view of a Control Engineer. The concepts acquired during the course will allow control engineers to make use of simulation tools for the development of basic and advanced control layer. The modules are prepared to approach the analysis to the given process making use of the different features of the simulator such as the Case Study to calculate gains or the event scheduler that will led to perform different case scenarios to see how the model behaves. Furthermore, the exercises show how to extract and use the available data in order to take the best advantage of the software capabilities. Some of the features that will be seen in the course are related to: distillation columns, sensitivity analysis, control strategy (feed forward, ratio controllers, split-range, master/slave...), function blocks, etc.

FOUR-DAYS COURSE AGENDA

MODULE	MODULE TITLE AND SHORT DESCRIPTION	TIME	DAY
1	<p>CREATING A STEADY-STATE MODEL</p> <p>A simple steady-state case of a real distillation column is created from basic data available at the plant. Details about simulator user interface, workflow, etc. Using different column specifications (reflux ratio, tray temperature, purity, etc.) to reproduce the degrees of freedom of the column. Use of mixers/tees to reproduce feed compositions. Extracting and visualizing data from the model (column profiles, tables) as a function of a variable.</p>	4 hours	Day 1
2	<p>USING A STEADY-STATE MODEL FOR GAIN ANALYSIS AND PROPERTY ESTIMATION</p> <p>Configuration of the "Case Study" functionality inside the simulation to perform sensitivity analysis of the built column for independent vs. dependent variables. Extraction of the data to Excel. Calculation of the Steady-State gains and non-linearity of the process. Another sensitivity analysis over the column is performed in order to obtain a regression of the product quality based on column pressures and temperatures.</p>	3 hours	
3	<p>TRANSITIONING A STEADY-STATE MODEL INTO A DYNAMIC MODEL</p> <p>Discussion of the main differences between the two simulation modes (Steady-State vs Dynamic) with regards to specifying equipment and flowsheet details. Concepts of Dynamic Simulation: Pressure-Flow solver, Pressure nodes, resistance equipment, etc. Rules for transitioning from a solved steady-state model to a dynamics one. Transition of the distillation column model to Dynamics mode. The column is ready for the next day to be operated with all the valves in manual mode.</p>	4 hours	Day 1 / Day 2
4	<p>ACTIVATING PID CONTROLLERS IN THE DYNAMIC MODEL</p> <p>Operation of the column in Manual mode for few minutes. Introducing basic PID controllers and split range controller into the model for automatic mass-energy balance regulation. Use of faceplates and trending stripcharts. Introduce basic perturbations to the model. Simulator PID object features. Basic tuning of column PID controllers. Optional: use of a commercial tuning tool.</p>	3 hours	Day 2
5	<p>CONFIGURING AN ON-OFF CONTROLLER</p> <p>Learn how to build and configure on-off controllers.</p>	0.5 hour	
6	<p>CONFIGURING A MASTER-SLAVE CONTROLLERS</p> <p>Learn how to build and configure cascade controllers in the distillation column model and test their benefits. Level-Flow control. Tray temp-reboiler duty control. Tune the new cascades.</p>	1.5 hours	
7	<p>CONFIGURING RATIO CONTROLLERS AND SELECTOR BLOCK</p> <p>Learn how to build and configure in the distillation column a Ratio controller and override logic structures for different operation purposes.</p>	1 hours	
8	<p>CONFIGURING A FEED-FORWARD CONTROLLER</p> <p>Learn how to build and configure a Feed-forward controller for the reboiler duty to anticipate column load changes.</p>	1 hour	
9	<p>USING THE TRANSFER FUNCTION BLOCK</p> <p>Learn the multiple purpose uses of the transfer function block (TFB). Using TFB as signal generator for perturbations. Using TFB as a noise generator. Using TFB as a dead-time in analyser signal. Create a filter for a process variable in a spreadsheet.</p>	2 hours	

MODULE	MODULE TITLE AND SHORT DESCRIPTION	TIME	DAY
10	ADDING DETAILS TO THE DYNAMIC MODEL Learn how to configure a number of useful options in the simulator to increase the fidelity of the model with the real plant. This includes: Valve Characteristic, Elevation and hydraulic Static Head contribution, equipment nozzles, level taps, actuators of the control valves, heat losses, and valve stiction.	2 hours	Day 3
11	USING THE EVENT SCHEDULER Learn how to configure the event scheduler to run automatically a sequence of events, for example to simulate a sequence of automatic steps for MVs-FFs.	1 hour	
12	EXTRACTING DATA FROM THE DYNAMIC SIMULATION Learn how to configure the case to perform simulation runs and extract the data in formatted files.	1 hour	
13	IMPORTING EXTERNAL PROCESS DATA TO THE SIMULATION Learn how to configure and use a simulation macro to import historic process data from an Excel file as a boundary condition or controller Set-Point of a dynamic simulation. Applied case to the Feed Flow of the distillation column.	2 hours	
14	COMPARING PERFORMANCE OF TWO DIFFERENT CONTROL LAYOUTS Learn how to duplicate the dynamic process model to compare simulation runs with different control settings. Applied case to the built distillation column.	1 hour	
15	CONFIGURING SIMULATED INFERENTIALS IN THE DYNAMIC MODEL Learn how to setup the unbiased and biased inferentials calculations to reproduce the same calculations performed in the AspenIQ modules and verify the accuracy of the implemented inferentials and their tuning parameters.	1.5 hours	Day 4
16	CONFIGURING AN ASPEN DMCPLUS CONTROLLER IN HYSYS: STEP-TESTING Learn how to use the DMCplus controller object within HYSYS to perform virtual step-test in the built column distillation model of the simulator. Export the formatted data for the MPC identification package.	1.5 hours	
17	IDENTIFICATION AND DEPLOYMENT OF THE ASPEN DMC3 CONTROLLER WITH HYSYS Import the data set generated in HYSYS and follow the basic Identification and Deployment workflow with Aspen DMC3 Builder. The connection is configured using HYSYS as an OPC Server and the controller is deployed from the DMC3 Builder application. This module will be shown by the instructor (no hands-on practice) as a review of a standard identification and deployment process and giving the instructions to link a DMC3 controller to a HYSYS Dynamic model.	2 hours	

*The time for each module is an estimation and can be adjusted/modified by the instructor during the training to fulfill all the contents to be learnt.